



**HUNTEC
TECHNOLOGY**

**CASE STUDY 5:
POLLINGTON SOLAR FARM
POWER SYSTEM STUDIES**

Client: Hunttec Technology
Industry: Renewables
Plant Type: Solar Farm
Project: System Studies
Contract: Lump Sum
Date: 2016

**“SPE carried out a P28
Transformer Energisation
Study, G5/4 Stage 2
Harmonics Study and an
Earthing Study.”**

SPE was appointed by Hunttec Technology to undertake a series of power system studies for a new 4MW solar PV array installed at Pollington, UK.

SPE carried out a P28 Transformer Energisation study to identify any limitations on switching the system transformers using the PSCAD simulation package. After identifying the transient voltage dip exceeded normal P28 allowances, SPE liaised with the end client to discuss potential solutions to the system such as PIR's, pre-magnetization and energization from the LV side.

SPE created a model of the main power system and part of the DNO network in ETAP, before carrying out a Stage 2 G5/4 harmonics study to assess the impact of the PV array on the DNO network. This included representing the background harmonic levels and output of the converters, against a variety of fault levels to ensure compliance with the DNOs available harmonic limits.

SPE also undertook a detailed analysis of the HV and LV earthing system using the CDEGS design package. After subcontracting a soil resistivity to a local company, SPE developed a detailed model of the soil layers, fault current return paths and the earth grid, before carrying out detailed Earth Potential Rise (EPR) calculations and detailed touch and step voltage calculations for the site.

Telephone: 01929 503041
Email: info@sp-eng.co.uk
Web: www.sp-eng.co.uk